

DIRECTORATE OF TECHNICAL EDUCATION

PORVORIM, GOA.

No. DTE/ESTT/4-10/2012/2566

Dated: 29 /10/2015

TENDER NOTICE

Director, Directorate of Technical Education, Porvorim, invites sealed tenders from the manufacturers/ authorized dealers of Exide/Amaron/Yuasa/Panasonic make batteries for the purchase and supply of 60 Nos. of UPS Batteries (including installation and commissioning) with buy back of existing 60 UPS Batteries.

Sr.No.	Name of Item	Specification	Qty
1.	Batteries (SMF) for three UPS of 10 KVA, with interlinking cable.	12 V/65AH, make Exide/ Amaron(Quanta)/ Panasonic /Yuasa.	60 Nos (set of 20 each)
Buy Back of existing 60 UPS Batteries situated at Directorate of Technical Education, Porvorim, Goa, having the following specification: 12 V 65 Ah. Interested parties/firms can inspect and verify the existing 60 Batteries of the three 10 KVA, UPS situated at the Directorate of Technical Education at Porvorim, Bardez, Goa during office hours from 9.30 AM to 5.45 PM .			
Opening of sale of Tender: 10.00 am of 30.10/2015.Closing of sale of Tender: 13.00 hrs of 23/11/2015. Closing of acceptance of Tender: 14.30 hrs of 23/11/15. Opening of Tender:16.00 hrs of 23/11/2015			

The technical specifications of required UPS Batteries are enclosed with this tender form as 'Annexure B'. Tenderers are advised to quote their rate after careful study of the technical specifications as well as the following terms and conditions:

TERMS AND CONDITIONS

Sealed envelope super scribed "Quotation for purchase and supply of UPS Batteries" containing the tender documents duly signed by the tenderer(s), other necessary documents as mentioned in this tender form should reach either by post or by person at the address given below on or before **23-11-2015 (14:30 Hrs)**

The Director,
Directorate of Technical Education
Porvorim, Bardez, Goa-403521
(Phone: 0832 2415106)

1. The interested bidders who wish to participate in the tender may download the tender form from the website www.dte.goa.gov.in or obtain the same from the office of the Directorate of Technical Education at Porvorim, Bardez, Goa during office hours. Following payments in the form of demand draft/pay order of any scheduled/nationalized bank payable at Porvorim, Goa:
 - a. Cost of Tender documents amounting to Rs. 100/-(non refundable) in form of (Cash/DD/Pay Order from Scheduled/Nationalized bank) drawn in favour of Director, Directorate of Technical Education, payable at Porvorim.
 - b. Earnest Money , amounting to Rs. 10,000/- must accompany the tender in the sealed cover super scribed "Quotation for purchase and supply of UPS Batteries" along with the reference number/date of Tender Notice as well as last date receipt & Opening of tenders. The quote must be addressed to the Director of Technical Education and put in tender box kept in Department for this purpose within the closing time & date specified.
2. Tenders received after due date and time stated above will not be entertained under any circumstances. DTE will not be responsible for any postal delay or misplacement of Tender documents sent by post.
3. Tenders will be opened at DTE on **23-11-2015 (16:00hrs)** in the presence of the interested tenderers or their authorized representatives whoever are present.

4. Tenderer (s) shall indicate complete specifications and all features of the UPS Batteries.
5. Tenderer's sending their tenders by mail/courier/post will do so solely at their risk and the Department will not be responsible for any loss in transit or postal delay.
6. Tender documents are not transferable.
7. Tenders should enclose inside the sealed cover all the following documents:
 - a. Cash receipt/DD towards cost of tender, DD/P.O/ towards Earnest Money, affixing rubber stamp at the back of EMD showing the name & address of firm/party as required.
 - b. Terms & Conditions of tender duly signed and also quote with declaration in 'Annexure A'.
 - c. Proof of manufacturing/authorized distributorship.
 - d. Proof of battery maintenance base in Goa.
8. In case the information submitted by the tenderer is found to be incorrect/false, at any stage, tender of such party will be rejected and not considered any further.
9. DTE reserves to itself the right to reject any or all the tenders without assigning any reason thereof and to call for any other details or information from any of the tenderers.
10. Director, Directorate of Technical Education, shall have the right to postpone/extend the date(s) of submission of tender /opening of bids.
11. The selected tenderer shall supply, install and calibrate the item with the existing UPS and remove the existing Batteries, within 15 days of the date of receipt of purchase order from DTE.
12. If the selected tenderer fails to supply, install and calibrate the UPS Batteries within the said period of 15 days, the Director shall be entitled to cancel the purchase order given to the tenderer without giving any notice and without any obligation whatsoever and make alternative arrangements for supply of the material.
13. Selected tenderer is liable to pay the required Service Tax/VAT/other taxes as are applicable, as may be decided by Central/State Governments from time to time. DTE shall not have any responsibility in this regard.

14. Only manufacturers of Exide, Amaron(Quanta), Panasonic or, Yuasa batteries or their authorized distributors can participate in the tender. The tenderer should submit proof of their manufacturing / authorized distributorship. This is subject to verification, if necessary.
15. The price must be quoted as per proforma for price schedule “**Annexure A**” both in words as well as in figures. It shall be inclusive of all applicable taxes, charges, levies, handling and transportation charges, etc. VAT and entry tax shall be indicated separately. Overwriting of rates should be avoided. Tenderer must initial any cutting / rewriting / overwriting of rates. Nothing over and above the quoted price would be payable to the successful bidder. Price quoted shall be valid for 60 days from the date of opening.
16. In case the firm fails to comply the purchase order within the stipulated period and are not willing to perform the contract, his EMD amount shall be forfeited and the item will be procured from the next lowest tenderer.
17. The bidder should carry an on-site **comprehensive warranty/guarantee** of the item for a period of at least 36 (thirty six) months. It shall be the duty of the contractual firm to replace/repair any of the non-functional Batteries during the Warranty/Guarantee period. Date of warranty/guarantee shall commence from the date of successful commissioning.
18. The installation and calibration of the new batteries with the existing UPS shall be done by qualified technicians having prior experience in dealing with UPS. The selected tenderer shall be fully responsible for any loss,

damage, expenses, if any, that may be caused to DTE due to any defective installation and calibration and such amounts shall be recovered from the contractor.

19. It is the responsibility of the bidder to take the 60 UPS batteries (under buy back) from DTE and no expenses will be borne by DTE.

20. Non-compliance with any of the conditions given herein may lead to the rejection of tender.

21. Successful bidder shall have to provide a performance guarantee of 10% of the amount quoted.

22. All disputes are subject to Panaji, Goa, jurisdiction, only.

Directorate of Technical Education
Alto-Porvorim
Bardez-Goa-403521

Tender No. DTE/ESTT/4-10/2012/2566

dated:29 /10/2015

ANNEXURE – A

Tender for purchase of 60 Nos. of UPS Batteries with interlinking cables (including installation and calibration) with buy back of existing 60 UPS Batteries.

I/We

.....her
eby certify that we are established manufacturers/ authorized distributors of
M/s.....

We hereby offer to supply, install and calibrate the following items as well as to buy back the existing 60 Nos. of UPS Batteries situated at DTE, Porvorim, Goa , at the prices indicated below:

Sl No.	Description of work/item	Qty.	Taxes applicable	Total price of the item(inclusive of all taxes, charges, levies, handling and transportation charges, installing, commissioning etc) with 36 months comprehensive on site warranty. (Rupees)	Total price for the buy back of 60 Nos of existing UPS batteries (Rupees)	Total Amount (ie Column e – Column f) (Rupees)
a	b	c	d	e	f	g
	Supply, Installation and Commissioning of UPS Batteries(SMF), with interlinking cables	60 nos				

It is hereby certified that I/we have understood all the terms and conditions specified in the tender document and are thoroughly aware of the nature of job required to be done and goods/items to be supplied. We agree to abide by all the tender terms and conditions. I/We hereby offer to carry out the job and supply the goods/items detailed above as per the tender terms and conditions.

(Signature and seal of Bidder)

Dated:

Directorate of Technical Education
Alto-Porvorim
Bardez-Goa-403521

Tender No. DTE/ESTT/4-10/2012/2566

dated:29 /10/2015

Annexure B

Technical specification of UPS batteries

Sr. No.	Description
1	The UPS Batteries should be Sealed Maintenance Free (SMF) batteries of the make Exide, Amaron(Quanta), Panasonic or, Yuasa.
2	The offered item shall be compatible to make calibration with the existing 10 KVA UPS
3	The container of SMF batteries should be of plastic body.
4	Guarantee/Warranty period of the batteries should not be less than 36 months.
5	The batteries should be able to supply stable supply of electricity to the computers and peripherals like printers attached to 10 KVA UPS
6	Capacity of the SMF battery shall be 65 AH/12V.
7	The firm should have a maintenance base in Goa .
8	Compatible interlinking cables should be provided .

